

Certificate of Conformity

LOT No : 0922264011
PACKAGING : 13.6 KG DISPOSABLE JUGS
BATCH No : A2226401CH

R134a - Refrigeration Grade

PROPERTIES	SPECIFICATIONS
Purity	99.8% (w/w), min
Water content	10ppm (w/w), max
Acidity % (as HCl)	1 ppm (w/w), max
Chloride ion test	1 ppm (w/w), max
Non-condensable gases	1.5% (v/v), max
Non Volatile Residue	100 ppm (w/w), max
Particulates and Solids	Colorless, clean

DATE: 21-SEPTEMBER-2022

CROSS REFERENCE TO CERTIFICATE OF ANALYSIS: ISO#1001033 - 325011033

QUALITY CONTROL DEPARTMENT



Prepared By: Aivie Barcenas



Checked By: Pradeep KC