



SHANDONG DONGYUE CHEMICAL CO., LTD.
TANGSHAN TOWN, HUANTAI COUNTY ZIBO CITY SHANDONG CHINA.

ANALYSIS CERTIFICATE

Goods Name: Refrigerant Gas R-410a --25Lb/11.3kg	Invoice No. DY230606 Batch No. 23060601
Sample Weight: 1,000g	Sample Time: 06.06, 2023
Sample Place: NO. 2 WORKHOUSE	Report Time: 06.06, 2023
Place of Origin: SHANDONG DONGYUE CHEMICAL CO., LTD.	

ANALYSIS RESULT

	AHRI700 Standard	Test Result
Purity, %(m/m)	99.5	99.98%
HFC-32, %		50.01%
HFC-125,%		49.97%
Moisture, % (m/m)	0.001	0.0009
Acidity, %(m/m)	0.0001	0
Evaporating Residue, %(V/V)	0.01	0.0009%
Chloride	--	Pass
Appearance	Bright & Clear	Pass
Non Condensable Gas, %(V/V)	1.5	0.89

Result of Inspection: EXCELLENT GRADE

Analyst: ZHANG LEI

Checker: SUN WEI

SHANDONG DONGYUE CHEMICAL CO. LTD.

