

ELECTRIC OIL CHARGING PUMP
OPERATION MANUAL
PCO-4/6



Please read this instruction carefully before using this product, and keep this manual carefully for future reference FEELING FOR MORE

WiPCOOL\*

## 1. Notice for Use

Thank you for buying WIPCOOL electric oil charging pumps, pls check if your ordered goods in good shipment condition, with the correct accessories.

This manual gives instructions on the correct installation, It's important that you follow this instructions carefully.

# 2. Caution

#### **A** WARNING

Before carrying out any adjustments or servicing, make sure the installation is disconnected from the power supply.

## **A**WARNING

Don't run this pump without oil .

Don't run in the place with explosion hazard and inflammables

## **A** WARNING

Don't touch the motor and pump after running long-time to prevent to scald the hand.

FEELING FOR MORE

# WIPCOOL\*

## 3. Product Introduction

#### 3.1 Product Overview

WIPCOOL electric oil charging pump is designed according to the feature of compressor oil supplement or change. It's body adopts with integration gear pump.

WIPCOOL electric oil charging pump is suitable for all kinds oil, especially for high viscosity oil and low temperature conditions; big flow rate, low noise, convenient carrying with toolbox, safety and reliability with thermal protection.

### 3.1.1 Scope of use

WIPCOOL electric oil charging pump is one of the special equipment used for refrigerant oil supplement and replacement of compressor. It can fill all kinds of refrigerant oil.

#### 3.1.2 Technical Data

Model	PCO-4	PCO-6
Voltage	230V~/50-60Hz 115V~/60Hz	230V~/50-60Hz 115V~/60Hz
Suit for oil viscosity	All kinds oil	All kinds oil (Especially high viscosity oil)
Motor	1/3 HP	3/4HP
Flow rate	150 L/h	350L/h
Max.Pressure	1.6MPa(232Psi)	2.5MPa(362psi)
Outlet port	1/4" & 3/8" SAE	1/4" & 3/8" SAE
Weight	5.6kgs	10.4kgs


#### FEELING FOR MORE

# **WIPCOOL**

#### 3.1.3 Accessories



#### 3.1.4 Product Indication Chart



01

0:

03

FEELING FOR MORE WIPCOOLT

#### 3.2 Operating Instruction

#### 3.2.1 Check Before Operation

(Only qualified service personal should operate this unit , may require the user to be licensed for some countries )

- Working-spot should have good lighting and Atmospheric conditions.
- Make sure the charging refrigerant oil from the oil tank is the same as the type indicated on the nameplate.
- Make sure with the correct voltage as the same as nameplate.

#### 3.2.2 Oil Charging Process

- Clean the inlet and outlet hose to protect the oil mix,connect to the oil pump,then insert the inlet hose to the tank.
- 2) Switch on the pump for suction oil and discharge the air from the inlet hose and pump body,then switch off the pump once make sure no air inside( Judgment Principle: The discharged oil has no foam or obvious air discharge noise, proves that the air has been discharged). Connect the outlet hose to the oil charging valve of compressor.
- 3) Open the oil charging valve, switch on the oil pump to start to charge the oil.
- Running the compressor to review if the oil level . pressure . oil temperature is under normally conditions, and do the adjustment if necessary.
- 5) Remove the oil tank .oil pump and outlet hose if everything is fine, wipe out the rest oil inside hose and pump. Pack them with sealed plastic bag ,then keep the compressor running again.

FEELING FOR MORE

# WiPCOOL\*

## 3.2.3 During Operation

#### 1) PCO-4 Oil Charging Pump

When the pressure in the pump is too high and the PCO-4 motor cannot operate normally at the rated speed, the oil return valve of the pump can be opened and then closed after the speed is normal, thus achieving the effect of instant pressurization.

#### 2) PCO-6 Oil Charging Pump

- When the charging pressure exceeds 2.5MPa, the pipeline safety relief valve opens. Oil flows back to the oil inlet through the return pipe to reduce the pressure of the outlet pipe.
- When the oil outlet pressure exceeds 5MPa, please stop charging and check whether the oil outlet pipeline is blocked.

FEELING FOR MORE

# WiPCOOL\*\*

## 4. Maintenance

### **A** WARNING

Before/during checking process, make sure the installation is disconnected from the power supply.

### **A** WARNING

Don't touch the pump while the unit is very hot after running long-time.

#### **A** WARNING

When the working pressure exceeds 5MPa, please stop charging and check whether the oil outlet pipeline is blocked.(PCO-6)

To ensure the long-life and performance of oil pump, it should need to use clean .pure refrigerant oil . Be sure to check first when the oil doesn't be used for a long time.

#### FEELING FOR MORE



## 5. Troubleshooting

	Problem	Cause	Action
	Solution pump Isn't operating At all	1.Power doesn't reach the pump 2.The voltage isn't correct 3.The thermal protector works 4.The temperature is too low 5.The pump body locked due to the dirt	Check the power and switch     Make sure to keep the input voltage within rated voltage ±5%     Check the thermal protector     Increase the invironment temperature
	Flow rate is too Small or cann't Pump anymore	1.The inlet hose or filte blocking 2.The system has the air 3.The outlet hose block 4.The oil level is too low 5.The system pressure is too high 6. Pump stored for a long time	1.Clean the inlet hose and filter 2.Discharge the air 3.Keep the outlet hose unblock 4.Check the inlet hose is under the oil Level or not 5.Solve the problem of high pressure 6. Pour a little oil from the pump inlet por
	Pump runs with high noise	too low oil level     unreasonable hose size     the dirt inside to pump     the system has the air     pump inner body damaged	1.check the inlet hose is under the oil level or not     2.adjust the hose size     3.repair the pump     4.discharge the air     5.repair the pump ,change the parts
	Pump temperature is too high	Work pressure is more than max. pump pressure     Ne enough fan cooling     The invironment temperature is too high     Poor ventilation	Read the manual carefully,re-select the model     Check the motor fan runs well or not     Decrease the invironment temperature     Improve ventilation

04 05 06 07