



BEST INC. LIMITED

ROOMS 1318-20 13/F HOLLYWOOD PLAZA, 610 NATHAN ROAD, MONGKOK, KOWLOON, HONG KONG

CERTIFICATE OF ANALYSIS

R134A

To: DAYAN REFRIGERATION SUPPLIERS LTD.
HOLON POB 1829-ZIP CODE 5811702- ISRAEL

Invoice No.:20220329-MIX
Date: APR.28,2022
PO NO: POB00528

By Vessel: MAERSK HALIFAX-217W
From:NINGBO, CHINA

Sales Contract No.: BEST20220329-MIX
To: HAIFA, ISRAEL

PRODUCT NAME: REFRIGERANT GAS R134A
QUANTITY: 740 CYLINDERS

SAMPLE DATE: 20220428
INSPECTION DATE: 20220428
EXPIRE DATE: 20230427
PRODUCTION LOT NUMBER:20220428

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

TEST ITEMS	SPEC.	RESULTS
Appearance	Bright & Clear Liquid.	Bright & Clear Liquid.
Purity (% by weight)	99.90 min	99.93
Water (% by weight)	0.0010 max.	0.00040
Acidity (% by weight)	0.0001 max.	0.00004
Non Condensables (% by volume)	1.0 max	0.1
High Boiling Residue (% by weight)	0.0100 max.	0.0032
Chloride (pass/fail)	pass	pass
Total Chlorofluoro Unsaturates (% by weight)	0.0040 max	0.0010

For and on behalf of
CONCLUSION: CONFORMITY
BEST INC. LIMITED
卓越興業有限公司

.....
Authorized Signature(s)