



Bestcool

BEST INC. LIMITED

ROOMS 1318-20 13/F HOLLYWOOD PLAZA, 610 NATHAN ROAD, MONGKOK, KOWLOON, HONG KONG

CERTIFICATE OF ANALYSIS

R404A

To: DAYAN REFRIGERATION SUPPLIERS LTD.
HOLON POB 1829-ZIP CODE 5811702- ISRAEL

Invoice No.: 20171211
Date: DEC.28, 2017
PO NO: PO702634

By Vessel: YM WINDOW 010W

Sales Contract No: BEST20171211

From: NINGBO, CHINA

To: ASHDOD, ISRAEL

PRODUCT NAME: REFRIGERANT GAS R404A

QUANTITY: 180 CYLINDERS

SAMPLE DATE: 20171227

INSPECTION DATE: 20171227

EXPIRE DATE: 20181226

PRODUCTION LOT NUMBER: 20171227

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

TEST ITEMS	SPEC.	RESULTS
Appearance	Colorless no turbid	Colorless no turbid
Smell	No strange stench	No strange stench
Purity	≥99.90%	99.90 %
Moisture	≤0.002%	0.0008%
Acidity(as HCL)	≤0.0001%	0.0001%
Residue after evaporation	≤0.01%	0.0007%

For and on behalf of
BEST INC. LIMITED
CONCLUSION: CONFORMITY.

.....
Authorized Signature(s)