



# BEST INC. LIMITED

ROOMS 1318-20 13/F HOLLYWOOD PLAZA, 610 NATHAN ROAD, MONGKOK, KOWLOON, HONG KONG

## CERTIFICATE OF ANALYSIS

R134A

To: DAYAN REFRIGERATION SUPPLIERS LTD.  
HOLON POB 1829-ZIP CODE 5811702- ISRAEL

Invoice No.: 20170316  
Date: MAY. 17, 2017  
PO NO: PO700599

By Vessel: EVER LUCKY 1273W

Sales Contract No: BEST20170316

From: NINGBO, CHINA

To: ASHDOD, ISRAEL

PRODUCT NAME: REFRIGERANT GAS R134A

QUANTITY: 340 CYLINDERS

SAMPLE DATE: 20170516

INSPECTION DATE: 20170516

EXPIRE DATE: 20180515

PRODUCTION LOT NUMBER: 20170516

WE HERE BY CERTIFY THAT THE ABOVE PRODUCT WAS TESTED AND FOLLOWING RESULTS HAVE BEEN OBTAINED.

TEST ITEMS	SPEC.	RESULTS
Appearance	Bright & Clear Liquid.	Bright & Clear Liquid.
Purity (% by weight)	99.90 min	99.92
Water (% by weight)	0.0010 max.	0.0006
Acidity (% by weight)	0.0001 max.	0.00001
Non Condensables (% by volume)	1.0 max	0.1
High Boiling Residue (% by weight)	0.0100 max.	0.001
Chloride (pass/fail)	pass	pass
Total Chlorofluoro Unsaturates (% by weight)	0.0040 max	0.0010

CONCLUSION: CONFORMITY.

For and on behalf of

**BEST INC. LIMITED**

卓越興業有限公司

Authorized Signature(s)