

Certificate of Conformity

LOT No : 0922265011
PACKAGING : 13.6 KG DISPOSABLE JUGS
BATCH No : A2226501CH

R134a - Refrigeration Grade

| PROPERTIES | SPECIFICATIONS |
|-------------------------|--------------------|
| Purity | 99.8% (w/w), min |
| Water content | 10ppm (w/w), max |
| Acidity % (as HCl) | 1 ppm (w/w), max |
| Chloride ion test | 1 ppm (w/w), max |
| Non-condensable gases | 1.5% (v/v), max |
| Non Volatile Residue | 100 ppm (w/w), max |
| Particulates and Solids | Colorless, clean |

DATE: 22-SEPTEMBER-2022

CROSS REFERENCE TO CERTIFICATE OF ANALYSIS: ISO#1005532 - 325015532

QUALITY CONTROL DEPARTMENT



Prepared By: Aivie Barcenas



Checked By: Pradeep KC