

Certificate of Conformity

LOT No : 0921243011
PACKAGING : 13.6 KG DISPOSABLE JUGS
BATCH No : A2124301CH


R134a - Refrigeration Grade


PROPERTIES	SPECIFICATIONS
Purity	99.8% (w/w), min
Water content	10ppm (w/w), max
Acidity % (as HCl)	1 ppm (w/w), max
Chloride ion test	1 ppm (w/w), max
Non-condensable gases	1.5% (v/v), max
Non Volatile Residue	100 ppm (w/w), max
Particulates and Solids	Colorless, clean

DATE: 31-AUGUST-2021

CROSS REFERENCE TO CERTIFICATE OF ANALYSIS: ISO#1366580 – 312906580

QUALITY CONTROL DEPARTMENT


Prepared By: Aivie Barcenas


Checked By: Pradeep KC