



Wiring diagram:



## Technical specification:

- 1. All parts of fan should be properly assembled, no oil or dirt on the surface, no obvious distortion, mechanical damage and other defects.
- Fan rotation is flexible, no delay, no operation sound, no scratch and other undesirable phenomena.
- 3. The safety requirement of fan is performed according to GB12350-2009, the electrical strength is 1500Vmin, and the insulation resistance is not less than  $100M\,\Omega$  at room temperature.
- 4. Motor insulation class, F CLASS.
- 5.Motor protection level, IP54, fan protection level, IP2X.
- 6. The fan balance level is:  $\underline{1380} \pm 10 \text{Wr/min}$  high than G6.3, vibration value is less than 5.4mm/s.




	Product model	YDWF102L40P4-570N-500 S
)	product type	External rotor axial flow fan
	customer	以色列DAYAN
	Product number	
	certification	CE、CCC

## Condition of use:

- 1) voltage and frequency:  $\underline{1 \sim 230} \text{ V} \; \underline{\pm5} \; \% \; \underline{50} \; \text{Hz} \; \; .$
- 2) Lead cable:Terminal block, the recommended standard of lead wire is not less than  $0.75 \, \mathrm{mm}^2$ .
- 3) Installation position: vertical or upward.
- 4) ambient temperature:-40~65°C.

The external wiring diagram:



## Nameplate:

DYN-4E S500-M-F 230V/50Hz CL.F 460VV 2.2A 1380r/min 12μF/450V IP54 2018/07 CE

## Test data at free:

connection	UAC (V)±5%	F (Hz)	P1 (W) ±10%	I (A) ±10%	n (r/min) ±10%	Noise dB(A)
	1~230	50	460	2. 2	1380	71

		The signature	(date) (month) (year)		
state	Deliver before				
	After de confinación			Product Specification	
drawing				Froduct Specification	
audit					
	approval				