

Dayan Refrigeration Supplies Ltd
26 Ha-Sadna
5881524 HOLON
ISRAEL

Certificate of Analysis

Repeat printout

Date

26.03.2024

Purchase order item/date

POD00148 / 25.01.2024

Delivery item/date

88244544 000001 / 30.04.2024

Order item/date

2694005 000010 / 02.02.2024

Customer number

1259728

Material Code / Description

10303133 / Honeywell Refrigerant R404A 10.9kg JugCN

Batch 2121101401 / Quantity 80 EA

Inspection lot 414968 from 22.02.2022

Characteristic	Value	Lower Limit	Upper Limit
Acidity (as HCL), ppm	< 1	-	1
Assay %(w/w)	99,90	99,70	-
Chloride ppm(w/w)	< 1	-	1
GENETRON 125, % (W/W)	44,30	42,00	46,00
GENETRON 134A, % (W/W)	4,20	2,00	6,00
GENETRON143A,%(W/W)	51,50	51,00	53,00
Moisture ppm	7	-	10
Non-condensable gases %(v/v)	0,90	-	1,50
Non-volatile residue ppm(w/w)	7	-	100
Particulates and Solids	Colorless, clean	-	-

Dayan Refrigeration Supplies Ltd
26 Ha-Sadna
5881524 HOLON

Delivery item/date
88244544 000001 /
30.04.2024

Page
2

Batch 2121103101 / Quantity 80 EA

Inspection lot 510555 from 28.11.2023

Characteristic	Value	Lower Limit	Upper Limit
Acidity (as HCL), ppm	< 1	-	1
Assay %(w/w)	99,98	99,70	-
Chloride ppm(w/w)	< 1	-	1
GENETRON 125, % (W/W)	44,74	42,00	46,00
GENETRON 134A, % (W/W)	3,91	2,00	6,00
GENETRON143A,%(W/W)	51,35	51,00	53,00
Moisture ppm	7	-	10
Non-condensable gases %(v/v)	0,77	-	1,50
Non-volatile residue ppm(w/w)	5	-	100
Particulates and Solids	Colorless, clean	-	-

Batch 2121101402 / Quantity 240 EA

Inspection lot 522480 from 20.03.2024

Characteristic	Value	Lower Limit	Upper Limit
Acidity (as HCL), ppm	< 1	-	1
Assay %(w/w)	99,98	99,70	-
Chloride ppm(w/w)	< 1	-	1
GENETRON 125, % (W/W)	44,70	42,00	46,00
GENETRON 134A, % (W/W)	4,03	2,00	6,00
GENETRON143A,%(W/W)	51,27	51,00	53,00
Moisture ppm	6	-	10
Non-condensable gases %(v/v)	0,62	-	1,50
Non-volatile residue ppm(w/w)	5	-	100
Particulates and Solids	Colorless, clean	-	-

This is electronically printed from SAP system and no signature is required.