



Certificate of analysis

Batch N°: 286545-E10

Shipping note N°: IT-RD18-00264

Date:03/04/18

Product: R134a

Customer: DAYAN REFRIGERATION SUPPLIERS LTD - HOLON

Component	Analytical Results	Specification
Purity	99.90 %w	≥ 99.9 % w
Non-condensibles	0.8 % v	≤ 1.5 % v
Water	6 ppm	≤ 10 ppm

Note:

Date 03/04/18

Quality Control Laboratory

TAZZETTI S.p.A.
Lab. Controllo Qualità

Certificate of analysis

Batch N°:286595-E10

Shipping note N°: IT-RD18-00264

Date:03/04/18

Product: R407C

Customer: DAYAN REFRIGERATION SUPPLIERS LTD - HOLON

Component	Analytical Results	Specification
Purity	99.90 %w	≥ 99.8 % w
R32	22.26 % w	21-25 % w
R 125	25.37 % w	23-27 % w
R134a	52.32 % w	50-54 % w
Non-condensibles	0.60 % v	≤ 1.5 % v
Moisture	8 ppm	≤ 10 ppm

Note:

.....

.....

Date 03/04/18

Quality Control Laboratory

TAZZETTI S.p.A.
Lab. Controllo Qualità



Certificate of analysis

Batch N°: 286795-E10

Shipping note N°: IT-RD18-00264

Date:03/04/18

Product: R410A

Customer: DAYAN REFRIGERATION SUPPLIERS LTD - HOLON

Component	Analytical Results	Specification
Purity	99.90 %w	≥ 99.8 % w
R32	49.52 % w	48.5-50.5 % w
R125	50.38 % w	49.5-51.5 % w
Moisture	8 ppm	≤ 20 ppm
Non-condensibles	0.1 % v	≤ 1.5 % v

Note:
.....
.....

Date 03/04/18

Quality Control Laboratory

TAZZETTI S.p.A.
Lab. Controllo Qualità